

**THE MUNICIPALITY OF SOUTHWEST MIDDLESEX  
REQUEST FOR TENDER NUMBER: 2025-01  
ADDENDUM # 3 – NOVEMBER 28, 2024  
LIMERICK LANDFILL CLOSURE, FINAL COVER AND  
STORMWATER DRAINAGE WORKS  
BOTHWELL, ON**

---



**This addendum shall be incorporated into the tender submission and shall form a part of the contract documents.**

**Tenderers shall take this Addendum into consideration when preparing and submitting their Form of Tender.**

**Failure to acknowledge receipt of this addendum in Section 3, Item 3.1 of the Form of Tender may render your tender submission non-responsive.**

---

**QUESTIONS AND ANSWERS**

**Question 1:** Will the lowest bid be rejected if the bidder does not demonstrate that the soil quality and clay content meet the project requirements?

**Answer:** Yes.

**Question 2:** How will the lowest bidder get paid for the testing and reporting to be completed prior to contract award?

**Answer:** The bidders shall build in the applicable cost of testing and reporting in the bid cost. No separate payment will be made for this purpose.

**Question 3:** What is the deadline to submit soil test reports prior to contract award?

**Answer:** Three weeks from receipt of the award notification letter. Failure to meet this deadline may result in rejection of the Bid.

**Question 4:** Can you please advise if certain scope of work such as the clearing and grubbing portion, can begin before the March 31st, 2025 start date?

**Answer:** Yes. Following contract award, the successful bidder may initiate the work before March 31, 2025.

**Question 5:** Who will be responsible to complete a wildlife assessment and report to the area prior to clearing and grubbing?

**Answer:** The bidders shall build in the cost to retain a qualified biologist to complete wildlife inspection, assessment and reporting in the bid cost. A copy of the Report shall be submitted to the Municipality for review prior to clearing and grubbing. No separate payment will be made for this purpose.

**Question 6:** Can you please explain the scope of work & reasoning for Provisional Item 5.4 - Supply, Place and Compact Clayey Cover Soil As Make-up Fill (Section 6)?

---

**THE MUNICIPALITY OF SOUTHWEST MIDDLESEX**  
**REQUEST FOR TENDER NUMBER: 2025-01**  
**ADDENDUM # 3 – NOVEMBER 28, 2024**

---

**Answer:** As per description of this item on Section 1.3.1.1 (Overview of Work) on page 5 of the Tender Documents, this provisional item refers to “Supply, place and compact clayey soil cover as make-up fill to match top of waste lines and grades, as required”. For additional clarity, this item is for fill that may be needed to be placed prior to final cover layer placement if required to achieve the top of waste contours shown on Drawing 3.

**Question 7:** We are submitting our bid under a Limited Partnership, where corporate seals are not available and not legally required. Please confirm that a signature from a representative of the company that has the authority to bind the company will suffice in this submission. Referring to page 24/45 of 02\_2024-10-24 TENDER DOCUMENTS (FINAL) bid document.

**Answer:** A legal opinion to address this request will be provided by the Municipality’s legal representatives. A legal opinion will not be provided to this request before the bid closing date. The Municipality’s legal representatives will also need to review the articles of incorporation and any other relevant information to determine if the bid will be valid when a corporate entity attends the mandatory meeting and a parent company submits the bid.

**Question 8:** Coltsfoot Dr from Newbury to the site:

- a. Is it a Township road as well? **Answer:** Yes, for the portion under the Municipality’s boundaries.
- b. Is it a half load road as well? **Answer:** Yes, for the portion under the Municipality’s boundaries, from March 1<sup>st</sup> to May 1<sup>st</sup>.
- c. If not, would an entrance to the site off Coltsfoot be permitted to avoid half load restrictions on Limerick? **Answer:** Not applicable.

**END OF ADDENDUM # 3**