



March 13, 2026

### **ADDENDUM # 3**

#### **RFT-SM-008-26 – Glencoe Wastewater System Upgrades - Industrial Park Sewage Pump Station Upgrade**

**Note of Clarification:**

All controls are to be housed in CP-1.

**Note of Clarification:**

The generator vendor will not be providing the ATS. The ATS is to be provided by Eaton or an approved equal.

**Note of Clarification:**

The Surge Protection Device (SPD) can be provided within a NEMA 1 enclosure as it will be located within PP-1.